

Данные по автоматическим выключателям для защиты трехфазных генераторов переменного тока приведены в таблице 12.

Таблица 12

Мощность In генератора	S1	S2	S3	S3	S4	S4	S5	S5	S6	S6	S7	S7	S8	S8	S8
[kVA]	125	160	160	250	160	250	400	630	630	800	1250	1600	2000	2500	3200
[A]	R	R	R	R	In [A]	In [A]	In [A]	In [A]	In [A]	In [A]	In [A]	In [A]	In [A]	In [A]	In [A]
40					100										
50					100										
63	91	100	100	100	100										
100	144,5		160	160	200	160	250	320							
160	231,2				250		250	320							
200	289						320	630	630						
250	361						400	630	630	800					
315	455							630	630	800	1000				
400	578							630	630	800	1000				
500	723									800	1000	1600			
630	910										1000	1600			
800	1156										1250	1600			
1000	1445											1600			
1120	1617											1600			
1250	1804												2000		
1400	2021													2500	
1600	2309													2500	
2000	2887														3200